



שם המתקן	מבנה 9	מבנה טיפול בבוצה - חדר חשמל ראשי מ"נ	מבנה 21 מבנה חשמל ומפוחים - חדר חשמל מ"נ	מבנה 9 מבנה טיפול בבוצה - חדר חשמל ראשי מ"נ
שם הצרחה	-	MCC2	MCC3	LCG2
שם הצרחה	כניסה לכוח	לוח מתנעים	לוח מתנעים	לוח ד"ג
הספק הצרחה (kW)	540	97	55	388
זרם נומינלי הצרחה (A)	976	175	100	701
דגם סכמת פיגוד	-	-	-	-
מס' תכנית סכמת פיגוד	-	-	-	-

למכרז	D.Y.	D.Y.	G.R.	G.R.	09.08.21	0
למכרז	D.Y.	D.Y.	G.R.	G.R.	29.07.20	P0
מס' תאריך	תכנון	שרטוט	בקר	אשר	תיאור השינויים	
<b>לעיון</b>	<b>למכרז</b>	<b>לביצוע</b>	מהדורה/שינוי	פרויקט:		
<b>מט"ש קריית שמונה</b>						
שם התכנית: <b>מבנה טיפול בבוצה -9</b> <b>לוח ראשי מ"נ LC2</b> <b>תכנית חד קווית</b>						
levels in : m		drawing size		project number		
measures in: m		A2		1135		
scale : -		file number		drawing number		
8559\1135-82-00-003		1135-82-00-003		1135-82-00-003		

YANAI LTD  
Electrical Engineering

TEL-AVIV TEL : 03-6479256  
HAIFA TEL : 04-8422077  
BEER-SHEVA TEL : 08-6900053  
E-MAIL : yani@yanielecta.co.il

© DHV MED Ltd. All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted, in any form or by any means, without the prior written permission of DHV MED Ltd. and it may not be used without such permission for any work other than that one for which it was made.