



שם המתקן	מבנה 9		מבנה טיפול בבוצה- חדר חשמל ראשי מ"נ	מבנה טיפול בבוצה- חדר חשמל ראשי מ"נ
	שם הצרחה	מס' הצרחה	LCG1	LCG2
שם הצרחה	כניסה ללוח	-	לוח ד"ג	לוח ד"ג
הספק הצרחה (kW)	805	-	417	388
זרם נומינלי הצרחה (A)	1457	-	756	701
דגם סכמת פיקוד	-	-	-	-
מס' תכנית סכמת פיקוד	-	-	-	-

למכרז	D.Y.	D.Y.	G.R.	G.R.	09.08.21	0
למכרז	D.Y.	D.Y.	G.R.	G.R.	29.07.20	P0
מס'	תאריך	תכנון	שרטוט	בקר	אשר	תיאור השינויים
לעיון	למכרז	לביצוע	מהדורה/שינוי			

פרויקט: **מט"ש קריית שמונה**

שם התכנית: **מבנה טיפול בבוצה -9**

לוח ד"ג LCG
תכנית חד קווית

קוח:

DHV MED
ENVIRONMENT CONSULTING ENGINEERING
רח' גדי מנחה 1 ת.ד. 8058 אזור התעשייה החדש נתניה 42504
טל. 09-8852312 פקס. 09-8853901 www.dhvm.com

levels in : m	drawing size	project number
measures in: m	A2	1135
scale : -	file number	drawing number
	8559\1135-82-00-004	1135-82-00-004

YANAI LTD
Electrical Engineering

ינאי

■ TEL-AVIV TEL : 03-6479256
□ HAIFA TEL : 04-8422077
□ BEER-SHEVA TEL : 08-6900053
E-MAIL : yani@yanielecta.co.il

© DHV MED Ltd. All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted, in any form or by any means, without the prior written permission of DHV MED Ltd., and it may not be used without such permission for any work other than that one for which it was made.