



שם המתקן	מבנה 9		מבנה 2	מבנה 9
	מס' הצרחה	מס' הצרחה	בריכת ויסות שפכים- חדר חשמל מ"ג	חדר חשמל ראשי מ"ג
שם המתקן	כניסה 1 כלוח	כניסה 2 כלוח	לוח מתנעים	לוח מתנעים
הספק הצרחה (kA)	417	417	142	275
זרם נומינלי הצרחה (A)	756	756	256	500
דגם סכמת פיקוד	-	-	-	-
מס' תכנית סכמת פיקוד	-	-	-	-

למכרז		D.Y.	D.Y.	G.R.	G.R.	09.08.21	0
למכרז		D.Y.	D.Y.	G.R.	G.R.	29.07.20	P0
תיאור השינויים		אשר	בקר	שרטט	תכנן	תאריך	מס'
0	מחדורה/שינוי	○	לביצוע	○	למכרז	○	לעיון

פרויקט:

מט"ש קריית שמונה

שם התכנית:

מבנה טיפול בבוצה-9

מבנה טיפול בבוצה
לוח ד"ג LCG1
תכנית חד קווית

לקוח:

רח' גר מנהל 1 ת.ד. 8058 אזור התעשייה החדש נתניה 42504
טל. 09-8852312 פקס. 09-8853901 www.dhvm.com

levels in : m	drawing size	project number
measures in: m	A2	1135
scale : -	file number	drawing number
	8559\1135-82-00-005	1135-82-00-005

YANAI LTD
Electrical Engineering

TEL-AVIV TEL : 03-6479256
HAIFA TEL : 04-8422077
BEER-SHEVA TEL : 08-6900053
E-MAIL : yani@yanielecta.co.il

© DHV MED Ltd. All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted, in any form or by any means, without the prior written permission of DHV MED Ltd. and it may not be used without such permission for any work other than that one for which it was made.