



שם הממוקד	מבנים 5,9,18,15,19	מבנה 5 ת.ש. WAS/ RAS						מבנה 9 מבנה טיפול בבוצה, חשמל ומפוחים								מבנה 19 מטבח טיפול בוקמפוסט	מבנה 9 חדר חשמל	מבנה 18 מבנה מנהלה	מבנה 15 מתקן קליטת ביובית + מי נטל			-	-
		GAVXV0702 GATE VALVE	TLXYV0701 TELESCOPIC VALVE	TLXYV0702 TELESCOPIC VALVE	TLXYV0703 TELESCOPIC VALVE	GAVXV0801 GATE VALVE	GAVXV0803 GATE VALVE	UP-0801 הממתכת בוצה	GAVXV0802 GATE VALVE	GAVXV0804 GATE VALVE	BFXYV1101 BUTTERFLY VALVE	BFXYV1102 BUTTERFLY VALVE	BFXYV1103 BUTTERFLY VALVE	BFXYV1104 BUTTERFLY VALVE	BFXYV1105 BUTTERFLY VALVE				UP-1201 מערך כח קומפוסט	UP1 כוח שרתים	UP5 כוח שרתים		
מס' הצרחה	00							16.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	50	25	25	13	13	1.5	-	-
שם הצרחה	כניסה לכוח							30	0.9	0.9	0.9	0.9	0.9	0.9	0.9	90	40	40	23.5	23.5	3	-	-
הספק הצרחה (קא)	100	0.5	0.5	0.5	0.5	0.5	0.5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
זרם נומינלי הצרחה (A)	180	0.9	0.9	0.9	0.9	0.9	0.9	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
דגם סמכות פיקוד		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
מס' תכנית סמכות פיקוד		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

0	למכרז	D.Y.	D.Y.	G.R.	G.R.	09.08.21	0
0	למכרז	D.Y.	D.Y.	G.R.	G.R.	29.07.20	PO
0	תיאור השינויים						
0	מהדורה/שינוי						
<b>מט"ש קריית שמונה</b>							
<b>מבנה 9 - מבנה טיפול בבוצה לוז מתנעים MCC1 תכנית חד קווית</b>							
levels in : m		drawing size		project number			
measures in : m		A1		1135			
scale : -				drawing number			
file number				8559\1135-82-00-007			
E-MAIL : yani@yanielecta.co.il				1135-82-00-007			

YANAI LTD  
Electrical Engineering

TEL-AVIV TEL : 03-6479256  
HAIFA TEL : 04-8422077  
BEER-SHEVA TEL : 08-6900053  
E-MAIL : yani@yanielecta.co.il

© DHV MED Ltd. All rights reserved. This drawing is for informational purposes only and should not be used for construction without the approval of the design engineer.